Westbrook Energy Center Cumberland County Westbrook, Maine A-743-70-C-A

Departmental Findings of Fact and Order Air Emission License Amendment #2

After review of the air emissions license amendment application, staff investigation reports and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 M.R.S.A., Section 344 and Section 590, the Department finds the following facts:

A. Introduction

FACILITY	Westbrook Energy Center (Westbrook Energy)	
INITIAL LICENSE NUMBER	A-743-70-A-I	
LICENSE TYPE	Administrative Revision	
NAICS CODES	221112	
NATURE OF BUSINESS	Independent electricity and steam generation	
FACILITY LOCATION	Westbrook, Maine	
INITIAL LICENSE ISSUANCE DATE	August 12, 2003	
AMENDMENT ISSUANCE DATE	January 31, 2005	
LICENSE EXPIRATION DATE	August 12, 2008	

B. Application Classification

Westbrook Energy has requested an Administrative Revision to their Title V license in order to correct typographical errors. Conditions (17)D and (18)D of the original license referenced the Auxiliary Boiler when they were intended to refer to the Emergency Generator and the Diesel Fire Pump, respectively. The conditions are corrected below.

ORDER

The following replaces Condition (17)D of License A-743-70-A-I:

(1) D. Visible emissions from the Emergency Generator shall not exceed 20% opacity on a 6-minute block average. Compliance with the opacity limit for the Emergency Generator shall be demonstrated through EPA Test Method 9 found in 40 CFR Part 60, Appendix A.

Westbrook Energy Center Cumberland County Westbrook, Maine A-743-70-C-A

(2)

Departmental Findings of Fact and Order Air Emission License Amendment #2

The following replaces Condition (18)D of License A-743-70-A-I

60, Appendix A.	est Method 9 found in	40 CFR Part
DONE AND DATED IN AUGUSTA, MAINE THIS	DAY OF	2005.
DEPARTMENT OF ENVIRONMENTAL PROTECT	ΓΙΟΝ	
BY:		air Emission
PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON A	PPEAL PROCEDURES	
Date of initial receipt of application: <u>December 13, 20</u> Date of application acceptance: December 14, 2004	004	

Date filed with the Board of Environmental Protection:

This Order prepared by Rachel E. Pilling, Bureau of Air Quality.

2

D. Visible emissions from the Diesel Fire Pump shall not exceed 20% opacity on

a 6-minute block average. Compliance with the opacity limit for the Diesel Fire